

DESIGN APPRAISAL DOCUMENT

Date 9 January 2007	Quote this reference on all future communications LDSS/PAS/FITA/MF
------------------------	---

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F070090

This Design Appraisal Document forms part of the Certificate.

APPROVAL DOCUMENTATION

Danish Institute of Fire Technology (DIFT) (formerly DANTEST), Copenhagen, Denmark, Fire Test Report No. PG10842 dated 15 June 2001.

CONDITIONS OF CERTIFICATION

1. System consists of: steel bulkhead insulated on one side with 65mm Rockwool Marine Firebatts 130 (thickness 65mm, density 130kg/m³) over plating and 30mm Rockwool Marine Wired Mat 105 (thickness 30mm, density 105kg/m³) over stiffeners. Retained to substrate with welded steel pins 3mm diameter and 38mm steel spring washers spaced at 300mm maximum centres.
2. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.

PLACE OF PRODUCTION

Rockwool A/S
Hovedgaden 501
2640 Hedehusene
Denmark



Martin Farrier
Lead Specialist
Product Approval Services
London Design Support Services
Lloyd's Register EMEA

Supplementary Type Approval Terms and Conditions

This certificate and Design Appraisal Document relates to type approval, it certifies that the prototype(s) of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein, it does not mean or imply approval for any other use, nor approval of any products designed or manufactured otherwise than in strict conformity with the said prototype(s).