



# NIPPON KAIJI KYOKAI

## Certificate

Certificate No.  
10EQ620FPA(R)-1

OF

### APPROVAL

Item : A-60 class bulkhead

Type : A-60 Bulkhead 2×30mm Rockwool Marine Firebatts 130

Specification : See Annex.

Manufacturer : Rockwool A/S  
Hovedgaden 501, 2640 Hedehusene, Denmark

Testing standard : FTP Code Annex1 / Part 3

Test report  
Test laboratory : Danish Institute of Fire and Security Technology  
Report number : G10096

THIS IS TO CERTIFY that the above type of products has been approved by Nippon Kaiji Kyokai with type approval No. 96FPA16DA, and that the products of the above type will be accepted for use onboard ships classed with the Society as complying with the relevant requirements of the Society's *Rules for the Survey and Construction of Steel Ships* and those of the *International Convention for the Safety of Life at Sea, 1974, as amended*, subject to the approval of the flag Administration and conditional upon the manufacturer having a quality control system audited by a competent authority to ensure continuous compliance with the type approval conditions.

This certificate is valid until 24th September, 2015.  
Issued at Tokyo on 15th November, 2010.


NIPPON KAIJI KYOKAI



H. Takano  
General Manager

Material and Equipment Department

Initial approval date : 25th September, 1996




Rockwool A/S

Date: 13.12.1995

A-60 bulkhead  
fire insulated with  
2x30 mm Rockwool Marine Fire batts 130.

Drawing nr.:

1b




Rockwool A/S

A-60 bulkhead  
fire insulated with  
2x30 mm Rockwool Marine Fire batts 130.

Drawing nr.:

2b

Date: 13.12.1995



Rockwool A/S	A-60 bulkhead fire insulated with 2x30-mm Rockwool Marine Fire batts 130.	Drawing nr.:
Date: 13.12.1995		3b