



CHECKED BY:
Richard Earle

The -
Loss Prevention
Council
DATE:
9 May 1991

- (1) Profiled Steel, 1.6mm (nom) thick.
- (2) Rockwool CONLIT FIREWALL SLAB - infill to troughs.
- (3) Rockwool CONLIT FIREWALL SLAB - 2 x 50mm, joints staggered between adjacent layers.
- (4) Reinforced Aluminium Foil to Slab.
- (5) Welded Steel Pins, 3mm (nom) @ 300mm (max) ctrs along troughs.
- (6) Wire Netting.
- (7) Steel Washers, 38mm (nom) diameter.

Rockwool Limited Pencoed Bridgend Mid Glamorgan CF35 6NY Telephone .0656 862621	Title : H60 FIREWALL (FIRE RISK EITHER SIDE)	
	View : PLAN	NOT TO SCALE
	Date : 13 May 1991	Drg No : CHC60FW/NR iss.1